

Project:

Committed:

Customer:

Drawer:

Date:

DEUMID. AD150E-AD300E-AD450E

AD0104E

-

01

04/11/2013

Exercise tension:	230Vac + 1Ph + N + PE
Auxiliary tension	230Vac
Frequency	50Hz
Nominal current	6,64A - 9,64A - 19,32A
Total power	1,54KW - 2,24KW - 4,46W
Protection level	IP44



TECNOFRIGO TUSCANY srl

Via J.F.Kennedy, 25/27/29 - 56020 Z.Ind.Fontanelle

Capanne - Montopoli Val D'Arno (Pisa)

Tel. +39 0571 467351 Fax +39 0571 469217

e-mail: info@tftdryair.com - www.tftdryair.com

- ☐

AD150E
- ☐

OPTION 1 - KIT HUMIDISTAT WITH DUCT PROBE RANGE 0-100%
- ☐

AD300E
- ☐

OPTION 2 - KIT HUMIDISTAT WITH WALL PROBE RANGE 20-90%
- ☐

AD450E

1	Aggiornato connessione ventilatori per comando umidostato	14/12/2017			
2	Aggiornato nuovo sezionatore MAN-OFF-AUTO	27/05/2019			
Rev.	Changes	Date	Prepared	Verified	Approved

